

CPC High Point School

1 High Point Center Way
Morganville, NJ 07751

Analytical Results for Lead

JR Henderson Labs, Inc.
123 Seaman Ave.
Beachwood, NJ 08722
732-341-1211
Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

CPC High Point School
1 High Point Center Way
Morganville, NJ 07751

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
26-3082-01	Field Blank	5-23-26	11:43	LEAD	200.8	<0.30	6/11/2026	9:18	15
26-3082-02	Bldg. #1-Health Office-Room 133	5-23-26	11:46	LEAD	200.8	<0.30	6/11/2026	9:27	15
26-3082-03	Bldg. #1-Room 103	5-23-26	11:48	LEAD	200.8	1.36	6/11/2026	9:30	15
26-3082-04	Bldg. #1-Room 121	5-23-26	11:50	LEAD	200.8	<0.30	6/11/2026	9:33	15
26-3082-05	Bldg. #1-Room 104	5-23-26	11:52	LEAD	200.8	<0.30	6/11/2026	9:36	15
26-3082-06	Bldg. #1-Room 232	5-23-26	11:54	LEAD	200.8	<0.30	6/11/2026	9:39	15
26-3082-07	Bldg. #1-Room 248	5-23-26	11:56	LEAD	200.8	1.34	6/11/2026	9:42	15
26-3082-08	Bldg. #3-Room 201 TS	5-23-26	12:03	LEAD	200.8	0.41	6/11/2026	9:45	15
26-3082-09	Bldg. #3-Room 201 DW	5-23-26	12:04	LEAD	200.8	1.45	6/11/2026	9:55	15
26-3082-10	Bldg. #3-Room 205	5-23-26	12:09	LEAD	200.8	<0.30	6/11/2026	9:58	15
26-3082-11	Bldg. #4-Room 421	5-23-26	12:14	LEAD	200.8	1.03	6/11/2026	10:01	15
26-3082-12	Bldg. #2-Kitchen	5-23-26	12:18	LEAD	200.8	<0.30	6/11/2026	10:04	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
< = less than

Examined By: *Margaret Ellis*
Lab Manager

Date: 6-11-26

CPC High Point School

1 High Point Center Way, Morganville

Lead Results

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
	Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
1	Field Blank	N	26-3082-01	JRH Labs	15083	5/23/2026	11:43	200.8	6/11/2026	9:18	<0.30	0.30	1	N	
2	Bldg. #1-Health Office-Room 133	N	26-3082-02	JRH Labs	15083	5/23/2026	11:46	200.8	6/11/2026	9:27	<0.30	0.30	1	N	
3	Bldg. #1-Room 103	N	26-3082-03	JRH Labs	15083	5/23/2026	11:48	200.8	6/11/2026	9:30	1.36	0.30	1	N	
4	Bldg. #1-Room 121	N	26-3082-04	JRH Labs	15083	5/23/2026	11:50	200.8	6/11/2026	9:33	<0.30	0.30	1	N	
5	Bldg. #1-Room 104	N	26-3082-05	JRH Labs	15083	5/23/2026	11:52	200.8	6/11/2026	9:36	<0.30	0.30	1	N	
6	Bldg. #1-Room 232	N	26-3082-06	JRH Labs	15083	5/23/2026	11:54	200.8	6/11/2026	9:39	<0.30	0.30	1	N	
7	Bldg. #1-Room 248	N	26-3082-07	JRH Labs	15083	5/23/2026	11:56	200.8	6/11/2026	9:42	1.34	0.30	1	N	
8	Bldg. #3-Room 201 TS	N	26-3082-08	JRH Labs	15083	5/23/2026	12:03	200.8	6/11/2026	9:45	0.41	0.30	1	N	
9	Bldg. #3-Room 201 DW	N	26-3082-09	JRH Labs	15083	5/23/2026	12:04	200.8	6/11/2026	9:55	1.45	0.30	1	N	
10	Bldg. #3-Room 205	N	26-3082-10	JRH Labs	15083	5/23/2026	12:09	200.8	6/11/2026	9:58	<0.30	0.30	1	N	
11	Bldg. #4-Room 421	N	26-3082-11	JRH Labs	15083	5/23/2026	12:14	200.8	6/11/2026	10:01	1.03	0.30	1	N	
12															

Chain of Custody

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

CLIENT INFORMATION

Name: CPC Integrated Health
Address: 10 Industrial Way, Suite 108
 Eatontown, NJ 07724
Client Rep: Rick Gonzalez 732-666-2541

LAB INFORMATION

Name: JR Henderson Labs, Inc.
Address: 123 Seaman Ave., Beachwood, NJ 08722
Lab Mgr.: Trevor Ellis

SCHOOL/PROJECT INFORMATION



Bldg : CPC High Point School
Bldg No:
Bldg Address: 1 High Point Center Way, Morganville, NJ 077751
Contact Name & Number: Rick Gonzalez 732-666-2541

SAMPLE DATA - ID & Location must match container label

Sample ID	Sampled Outlet Location	Date	Time (24hr)	First Draw	Flushed
26-3082-01	Field Blank	5/23/26	11:43	X	
26-3082-02	BLDG. 1 / HEALTH OFFICE / ROOM 133	5/23/26	11:46	X	
26-3082-03	BLDG. 1 ROOM 103	5/23/26	11:48	X	
26-3082-04	BLDG. 1 ROOM 121	5/23/26	11:50	X	
26-3082-05	BLDG. 1 ROOM 105 104	5/23/26	11:52	X	
26-3082-06	BLDG 1 ROOM 232	5/23/26	11:54	X	
26-3082-07	BLDG 1 ROOM 248	5/23/26	11:56	X	
26-3082-08	BLDG 3 ROOM 201 TS	5/23/26	12:03	X	
26-3082-09	BLDG. 3 ROOM 201 DW	5/23/26	12:04	X	
26-3082-10	BLDG 3 ROOM 205	5/23/26	12:09	X	
26-3082-11	BLDG 4 ROOM 421	5/23/26	12:14	X	
26-3082-12	BLDG 2 KITCHEN	5/23/26	12:18	X	

All containers are pre-cleaned/ 250 ml plastic bottles preserved w/ HNO₃ @ pH<2 to be preserved by lab

CHAIN OF CUSTODY

Relinquished By: 	Date/Time:	Received By: 	Date/Time: 5/27/26 10:36

Method of shipment/delivery: ☐ Fed-Ex ☒ Hand Delivery ☐ Other: _____

INSTRUCTIONS TO THE LABORATORY

Analyze both initial and follow up samples ☐ Other: ☒ Follow QAPP instructions	Lab: JR Henderson Labs 123 Seaman Ave. Beachwood, NJ 08722 Contact: Stacey Yuro syuro@henderson-labs.com	Report Results to: Phone ☒ Email: rgonzalez@cpcih.org
---	--	--

Comments: Provide Laboratory Data Report (LDR) Package and Chain of Custody